

Location: _____



DC

**IN LINE DUAL CHECK VALVE
LEAD FREE**

Specification: The BEECO In Line Dual Check Valve prevents the reverse flow of polluted water from entering into the drinking water supply. It is designed to be used in either the horizontal or vertical position and should be placed at the service entrance or can be used as a point of use device. This device is designed for continuous pressure applications in non-health hazard residential water system containment. It should be installed right after the water meter. Check with your local inspection authorities for installation requirements.

Materials: Bronze body and tailpiece construction, with Stainless Steel check springs and engineered plastic polymer check assemblies. Complies to AB 1953 Lead Free Standard.

Ratings:


- Minimum Working Pressure: 10psi (69 kPa)
- Maximum Working Pressure: 150psi (10 bar)
- Temperature Range: 33° F - 180° F (0.5° C - 82° C) continuous

Features:

- Contains two heavy replaceable check modules for ease of service or repair.
- End connections in both NPT and Copper sweat connections.
- Interchangeability of tail piece Inlet can 1/2" up to 1" outlet, and outlet can be 1/2" up to 1", allowing for changes in pipe size from inlet to outlet.

LEAD FREE

The wetted surface of this product contacted by consumable water contains less than 0.25% of lead by weight.



Model No.	Size	Connection Type
DC.50-NPTX.50-NPT-LL	1/2"	NPT X NPT
DC.75-NPTX.75-NPT-LL	3/4"	NPT X NPT
DC1.0-NPTX.75-NPT-LL	1" Inlet by 3/4"	NPT X NPT
DC1.0-NPTX1.0-NPT-LL	1"	NPT X NPT
DC.50-SWTX.50-NPT-LL	1/2"	SWT X NPT
DC.75-SWTX.75-NPT-LL	3/4"	SWT X NPT
DC1.0-SWTX.75-NPT-LL	1" Inlet by 3/4"	SWT X NPT
DC1.0-SWTX1.0-NPT-LL	1"	SWT X NPT
DC.75-FWMX-.75-NPT-LL	3/4"	FWM X NPT
DC1.0-FWMX-1.0-NPT-LL	1"	FWM X NPT

CALIFORNIA PROPOSITION 65 WARNING. This product contains chemicals known to the State of California to cause cancer and birth defects or other reproductive harm.

Job Name: _____ Page No: _____

Section No: _____ Contractor: _____

Schedule No: _____ Purchase Order No: _____